

157159

Monsanto

FROM
(NAME-LOCATION-PHONE) T. Carrico

DATE July 30, 1984
SUBJECT Status Report on
CEA 3808
REFERENCE
TO : P. Hoemann

cc: L. Bumbicks
K. Lichtenheld
R. Murphy
R. Nelson
O. Shipley

The four dewatering pumps were set by the plant by Tuesday, at 5th Street, near I Street - first four wells.

They have been checked for rotation and pumping capability - all OK.

No. 3 pump which discharges south of 5th Street at I Street seems to pump more water than the sewer box can handle. This is being looked at by CED.

Tom Carrico
Tom Carrico
Operation Foreman
Extension 2095

skg

WGK 4084906